



CLT3-4BT6 DEMOBOARD: CHECK THE ROBUSTNESS OF CLT3-4BT6

CONTENT

- DESCRIPTION OF THE CLT3-4BT6 PRODUCT
- CLT3-4BC6 DEMONSTRATION BOARD
- EMC REQUIREMENTS
- ROBUSTNESS AND IMMUNITY OF THE CLT3-4BT6 DEVICE
- CONCLUSION
- REFERENCES

1. DESCRIPTION OF CLT3-4BT6 PRODUCT

1.1. Functional description

The CLT3-4BT6 (Current Limited Termination) is a quadruple input digital termination device designed for 24V DC automation applications. It achieves the front-end circuitry of a digital input module (I/O) in industrial automation.

Available in a four channels configuration, it offers a high-density termination by minimizing the external component count. It is housed in a TSSOP20 surface mount package to reduce the printed board size.

Made of a parallel input voltage protection, a serial input-output current limiting circuit and an opto-coupler driver, each channel circuit terminates the connection between the logic input and the associated high side sensor or switch.

The CLT3-4BT6 device is used between the sensors and the opto-coupler of an input module. The current limiting circuit, connected between the input and the output pins, is compensated all over the temperature range. Furthermore, each channel runs independently of the other. Thanks to its low tolerance, the current limitation allows the drastic reduction of the dissipation compared to a resistive input: the overall module requires less cooling capability and becomes smaller.

The output block of each termination channel controls the operation of an opto-coupler that is internally enabled by a Light Emitting Diode. When the input current is less than 1.5mA, an integrated

output circuit derivates the input current to maintain the opto-coupler off.

When the CLT input voltage V_{IN} is higher than 5V (that corresponds to a module input voltage higher than 11V with a 1.2k Ω serial resistor), a minimum output current of 1.5mA secures the opto-coupler in the on state.

The CLT3-4BT6 protects the input module against transient electromagnetic interferences such as those described in the IEC61131-2 standard.

The opto-coupler plays a role in the CLT3-4BT6 operation. The drop voltage of its input diode introduces a voltage offset in series with the CLT3-4BT6 channel: for a good CLT3-4BT6 operation, this drop voltage should remain below 2V (see *CLT3-4BT6 datasheet* for more details).

1.2. Application requirements

A reverse blocking diode is connected between the module ground connection and the common pin COM of the CLT3-4BT6 device to protect the module against spurious reverse supply connection. This diode also protects the CLT3-4BT6 device against negative surge voltages.

An external output capacitor is placed either at the input or the output of the CLT3-4BT6 to filter the transient disturbances injected in the inputs of the module and secure the immunity of the module itself.

All immunity requirements are described by the IEC61131-2 international standard.

APPLICATION NOTE

2. CLT3-4BT6 DEMONSTRATION BOARD

2.1. Description of the CLT3-4BT6 demoboard

This CLT3-4BT6 demonstration board allows the evaluation of the function of the CLT3-4BT6 product. It can be easily inserted in a real application, between sensors and digital bus controller. The output LEDs give the state of each line of the CLT3-4BT6, according to the state of each input.

The PCB of the demonstration board has the structure described by the *figure 1*. It has been designed and optimized with the components presented in the *table 1*. This configuration gives a good example of a robust interface design.

Table 1: bill of material.

Reference	Nb	Part description	Package
J1, J2	2	Connector 6 pins	2.54 pitch
Rin1, Rin2, Rin3, Rin4	4	1.2 k Ω , 0.25 W	1206
RC	1	4.7 k Ω , 0.33 W	1206
C1, C2, C3, C4	4	22 nF, 60 V	1206
R_LED	1	4 resistors array 330 Ω , 0.13W	1206
LED1, LED2, LED3, LED4	4	LED 10 mA	1206
U1	1	CLT3-4BT6	TSSOP20
U2	1	TLP281-4	SO-16

The copper surface under the CLT device improves the thermal dissipation capability of the TSSOP20 package. The copper area on the PCB demoboard is around 1.2cm², and makes it possible to decrease the Rth of the package to a value lower than 100°C/W.

2.2. Operating instructions of the CLT3-4BT6 demo-board

This paragraph provides some basic advices to implement properly the demonstration board in order to evaluate the CLT3-4BT6 product.

■ Inputs / Outputs

The input connector gives access to the 4 input signals of the module (In1, 2, 3 and 4), and the power supply access of the CLT3-4BT6 (Vcc and Com). It is then easy to connect this module directly to any type of sensor, especially those specified by the EN60947-5-2 standard.

The output connector gives access to the 4 outputs of the module (output of the opto-coupler, Out1, 2, 3 and 4). Furthermore, this connector is also used to connect the output power supply (Vcc2 and

Com2). It is then easy to connect the output of the module directly on a digital bus controller.

■ Power supply

- Vcc power supply

The Vcc power supply shall be a 24Vdc voltage supply. Actually, the CLT3-4BT6 device needs a 10 to 30Vdc voltage to work.

- Vcc2 power supply

The output power supply can be a 5Vdc voltage supply. This voltage supplies the 4 collectors of each opto-coupler output.

NOTE: Do not short the opto-coupler output to ground. This may result in the destruction of the output transistor of this opto-coupler.

■ Discrete components

- Discrete capacitors:

Some 22nF capacitors are used in order to improve the noise immunity of the whole module and to filter the high frequency electrical noise in the off state.

They can be placed at the output of the CLT (between the CLT device and the opto-coupler) as described in the *datasheet*. This configuration meets the minimum level of immunity described in the IEC61131-2 standard. The configuration corresponding to capacitors placed at the input of the CLT device (between input resistors and the CLT device), as in the demonstration board topology, allows an increase of this immunity. However, the normal operation of the module remains within specification whatever the position of the capacitors is.

- Input resistors:

The input resistors are used in order to limit the current that could appear in case of voltage surge clamped by the CLT3-4BT6. These resistors shall then withstand the high overvoltage that may be applied to the module during surge tests.

- LEDs resistors:

The value of these resistors shall be set according to the input power supply value used, and the normal current of displaying LEDs. A resistor array can be used to control these low power LEDs (reducing of the PCB size).

- Diode D1:

The diode used between the COM of the input power supply, and the COM of the CLT3-4BT6 device can be a general purpose component as a 1000V 1A rectifier.

■ Opto-coupler

The opto-coupler should be chosen according to its input diode drop voltage and should fit the wide range output voltage of the CLT3 output (0.2V).

Fig. 1: Electrical diagram of the CLT3-4BT6 demonstration board for reinforced EMC.





Fig. 2: Assembly top view of the demonstration board.



3. EMC REQUIREMENTS

3.1. Description of the procedure to evaluate the robustness of the CLT3-4BT6

The reference to evaluate the robustness of the CLT3-4BT6 product is the IEC61131-2 international standard. This international standard gives all requirements and conditions of tests that must be performed on the programmable logic controllers PLC and their associated peripherals.

This paper focuses on the most stressfully tests for the CLT3-4BT6 product. The immunity of the CLT3-4BT6 is tested according to the standards.

The IEC61131-2 standard specifies the Electromagnetic Compatibility (EMC) requirements and the nature of the tests to perform in order to determine if the system meets these requirements (*paragraph 7: "EMC requirements" and paragraph 8: "EMC type tests and verifications" of the Ed2 of the standard*). The levels of each test depend on the zone where the system will be installed. The most typical industrial environmental levels correspond to zone B: local power distribution zone and dedicated power distribution zone (*see table 28: "EMC immunity zones" of the IEC61131-2-Ed2 standard*). The following paragraphs recall the test levels for this zone.

3.2. ESD tests (according to the IEC61000-4-2)

The electrostatic discharge test shall be applied to operator accessible devices. This means that these tests have to be performed on each connector pin.

The required levels are:

- air discharge: +/-8kV
- contact discharge: +/-4kV

The PLC system shall continue to operate as intended. Temporary degradation of the performance is acceptable during the test, but the system must recover by itself after the test (*B criterion according to the IEC61131-2 standard*).

3.3. Burst tests (according to the IEC61000-4-4)

The fast transient burst tests must be applied on all the input pins of the system. A capacitive clamp-coupling device (50-200pF) must be used as described in the IEC61000-4-4 standard.

The required burst voltage levels are:

- analog or dc I/O: +/-1kV,
- dc power line: +/-2kV.

The PLC system shall continue to operate as intended. Temporary degradation of the performance is acceptable during the test, but the system must recover by itself after the test (*B criterion according to the IEC61131-2 standard*).

3.4. Surge test (according to the IEC61000-4-5)

Since the voltage surge consists in a single but energetic pulse, the CLT3-4BT6 device embeds an over-voltage protection on each point. The absorbed energy complies at least with the requirements of the IEC61131-2 standard. The high energy surge test must be applied on all input pins of the system. For all analog inputs, the coupling method is a 47 Ω serial resistance and a 0.5 μ F capacitor. For dc power line, the coupling is 2 Ω , 18 μ F with differential mode, and 12 Ω , 9 μ F with common mode.

The required voltage surge levels are:

- analog or dc I/O: 0.5kV (line to line and line to earth coupling modes),
- dc power line: 0.5kV (line to line),
- dc power line: 1kV (line to earth).

The PLC system shall continue to operate as intended. Temporary degradation of the performance is acceptable during the test, but the system must recover by itself after the test (*B criterion according to the IEC61131-2 standard*).

3.5. Conducted disturbance tests (according to the IEC61000-4-6)

The conducted radio frequency interference test must be applied on all input pins of the system. The frequency range is 150kHz to 80MHz, with a 80% amplitude modulation by a 1kHz sinusoidal wave.

A CDN (Coupling Device Network) or a current coupling clamp (as described in the IEC61000-4-6 standard) has to be used to apply the stress to the system.

The required level is:

- 3Vrms, whatever the tested system input is.

The PLC system shall continue to operate as intended. No loss of function or performance is acceptable (*"A" criterion according to the IEC61131-2 standard*).

3.6. Reverse analog input polarity tests

The test procedure is described by the IEC61131-2 standard (*paragraph 5.4.4.5 of the Ed2 of the standard*). A signal of reverse polarity (negative voltage) for unipolar analog inputs is applied for 10s. The result of this test shall be as stated by the manufacturer.

Each input of the CLT3-4BT6 device may be biased to a reverse polarity. This case corresponds to a connection mistake, or a reverse biasing that is generated by the demagnetization of a monitored inductive solenoid.

The involved input withstands the high reverse current up to 20mA; its opto-coupler is off and protected by the conducting input diode. The other inputs remain operational, and some extra dissipation can happen in their clamping protections.

Considering the supply operation, a reverse blocking diode can be connected between the module ground and the common pin COM to protect the CLT3-4BT6 device against any spurious reverse supply connection. Then, the whole module supply voltage rating is extended to +/-30V.

The thermal management of this accidental situation, is described in the §5.

4. ROBUSTNESS AND IMMUNITY OF THE CLT3-4BT6 DEVICE

The table 2 shows the minimal requirements of the IEC61131-2 Ed2 international standard. Furthermore, it gives an overview of the high immunity that a CLT3-4BT6 device will ensure to the whole interface module.

Table 2: Immunity of the CLT3-4BT6 device.

	Minimum requirements of international standards			Robustness of the CLT3-4BT6 demoboard			
	Tests conditions	Levels		Tests conditions	Levels	Behavior of the CLT	
ESD test IEC61000-4-2	Air discharge	± 8kV		RC = 4.7kΩ RIN = 1.2kΩ	± 8kV	No failure, no disturbance	
	Contact discharge	± 4kV		RC = 4.7kΩ RIN = 1.2kΩ	± 6kV		
Burst test IEC61000-4-4	Analog input	± 1kV		RIN = 1.2kΩ	C = 22nF ± 4kV	No failure, no disturbance	
	DC power line	± 2kV		RC = 4.7kΩ			
Surge test IEC61000-4-5	Analog input	42Ω, 5μF differential and common mode	± 0.5kV	Analog input	RIN = 1.2kΩ	No failure, temporary disturbance	
		DC power line	2Ω, 18μF differential mode				± 0.5kV
	12Ω, 9μF common mode		± 1kV		± 1kV		
Conducted disturbance test IEC61000-4-6	150kHz to 80MHz	22nF capacitors at the output	3VRMS AM ± 80%	150kHz to 80MHz	RIN = 1.2kΩ C = 22nF at the INPUT	10VRMS AM ± 80%	No failure, no disturbance
Reverse input polarity test	-Vcc applied to one input during 10s			-30VDC applied to one input, +30VDC on the others		No failure, no cross talk	

5. THERMAL MANAGEMENT

The CLT3-4BT6 device limits the current that flows across each line. This causes an increase of the junction temperature. The maximal allowed junction temperature of the CLT3-4BT6 is 150°C.

The TSSOP20 package has a thermal resistance specified in the datasheet. This parameter allows the determination of the maximal ambient temperature during the operation of the device.

The ambient temperature to take into account is obviously the air temperature close to the component.

The main equation corresponds to the following:

$$\Delta T_{j-a} = T_j - T_a = P_d \cdot R_{th_{j-a}}$$

With:

- T_j: junction temperature,
- T_a: ambient temperature,
- P_d: power to dissipate,
- R_{th_{j-a}}: junction to ambient thermal resistance.

This paragraph presents the method to evaluate the dissipated power, and also the evolution of the R_{th} value versus the copper surface on the PCB.

The maximal ambient temperature fixes the maximal allowed ΔT_{j-a}. To estimate the maximal power dissipation, it is possible to refer to the parameter of the datasheet that gives the maximal specification of the limitation of current. The purpose is to make the sum of all "thermal supplies" inside the die.

There are 3 main sources origins of the power dissipation: the 2 current limiters embedded in each line of the CLT device (see figure 3 on page 6), and the low current consumption of the V_C pin (I_C).

Then, the maximal power dissipation can be estimated as follow:

$$P = 4 \cdot [(V_{CLT} \cdot 0.75 \cdot I_{IN}) + (V_{IN} \cdot 0.25 \cdot I_{IN})] + V_C \cdot I_C$$

The worst case scenario occurs when I_{IN} and I_C are maximal. These maximal values are given in the datasheet:


$$I_{IN} = 3.7mA$$

$$I_C = 800\mu A$$



APPLICATION NOTE

Fig. 3: Equivalent circuit of 1 line when the CLT3-4BT6 limits the current.



To calculate the drop voltage across the CLT device, the circuit of *figure 3* gives the following equations:

$$V_{IN} = V_{CC} - V_{SENSOR} - R_{IN} \cdot I_{IN}$$

$$V_{CLT} = V_{IN} - V_{OUT}$$

The worst case scenario corresponds to the maximal supply voltage value (V_{CC}), and to the minimal drop voltage across the sensor (V_{SENSOR}) and across the diode of the opto-coupler (V_{OUT}).

For example:

- $V_{CC} = 30V_{max}$
- $V_{SENSOR} = 0V_{min}$
- $V_{OUT} = 0.7V_{min}$

$$\Rightarrow P_{TOTAL} = 395mW$$

In case of a maximal allowed ambient temperature equal to $100^{\circ}C$, the thermal resistance must be lower than $127^{\circ}C/W$. Since the maximal R_{th} value of the TSSOP20 package ($0cm^2$) is $120^{\circ}C/W$, The CLT3-4 runs correctly at this ambient temperature.

But, there is another case to take into account, with higher power dissipation: spurious reverse supply connection (see §3.6). In that case, it is possible to take as a reference the *figure 6* of the *datasheet* that gives typical currents in this case. For example, referring to current and clamping voltage described by the *datasheet*, we can consider:

$$P_{TOTAL} = 3 \cdot (V_{CL} \cdot I_{IN}) + V_{CC} \cdot I_{CC} + V_D \cdot I_4$$


With I_4 corresponding to the current in the line with the reverse connection supply: $I_4 = I_1 + I_2 + I_3 + I_C$. This current flows across the diode, and causes the drop voltage V_D .

$$\Rightarrow P_{TOTAL} = 528mW$$

In case of a maximal allowed ambient temperature equal to $100^{\circ}C$, the thermal resistance must be lower than $95^{\circ}C/W$.

The *figure 4* is taken from the *datasheet* of the CLT3-4BT6 device. It gives the junction to ambient thermal resistance as a function of the copper surface used as a heatsink (FR4 epoxy PCB, $35\mu m$ for the thickness of the copper). The $95^{\circ}C/W$ can be reached with the use of $1.6cm^2$ of copper surface.

Fig. 4: Typical junction to ambient thermal resistance versus PCB layout surface for the TSSOP20.



As an example, the copper surface on the demo board is equal to $1.2cm^2$ allowing operation ambient temperature up to $100^{\circ}C$.

6. CONCLUSION

The demonstration board allows the evaluation of the robustness of the CLT3-4BT6 product against electromagnetic disturbances.

Thanks to the use of the CLT3-4BT6, the immunity of a PLC system exceeds the requirement standard levels, providing an extra safety to the application.

Furthermore, the demo board shows the functional characteristics of this new product, and gives an example of application.

The layout has been designed as versatile as possible, and can be used in most industrial or automotive applications.

7. REFERENCES

- Datasheet of the CLT3-4BT6 product.
- EN60947-5-2: "Low-voltage switchgear and controlgear - Part 5-2: Control circuit devices and switching elements - Proximity switches".
- IEC61131-2: "Programmable controller; Part2: Equipment Requirements and tests".
- IEC61000-4-2: "Electrostatic discharge immunity test".
- IEC61000-4-4: "Electrical fast transient/burst immunity test".
- IEC61000-4-5: "Surge immunity test".
- IEC61000-4-6: "Immunity to conducted disturbances, induced by radio-frequency fields".

Information furnished is believed to be accurate and reliable. However, STMicroelectronics assumes no responsibility for the consequences of use of such information nor for any infringement of patents or other rights of third parties which may result from its use. No license is granted by implication or otherwise under any patent or patent rights of STMicroelectronics. Specifications mentioned in this publication are subject to change without notice. This publication supersedes and replaces all information previously supplied.

STMicroelectronics products are not authorized for use as critical components in life support devices or systems without express written approval of STMicroelectronics.

The ST logo is a registered trademark of STMicroelectronics

© 2002 STMicroelectronics - Printed in Italy - All rights reserved.

STMicroelectronics GROUP OF COMPANIES

Australia - Brazil - Canada - China - Finland - France - Germany
Hong Kong - India - Israel - Italy - Japan - Malaysia - Malta - Morocco - Singapore
Spain - Sweden - Switzerland - United Kingdom - United States.

<http://www.st.com>

